



International meeting
EQUIPMENT QUALIFICATION IN NUCLEAR INSTALLATIONS

Two qualification campaigns of sealing types for nuclear application

F. Destaing*, L. Biringe**, E. Sauger*, J. Leray*

*CETIM,

74 route de la Jonelière 44326 Nantes, France

Fanny.destaing@cetim.fr

**EDF - DIPNN - DT - CEE

19 rue Pierre Bourdeix – CS 803269363 - LYON CEDEX 07 (France)



Outlook

- Quick presentation of CETIM
- Campaign 1 : Qualification of low friction valve packings for nuclear applications
 - Work program
 - Testing facilities
 - Results
 - Conclusions
- Campaign 2 : Qualification of static and semi-dynamic O-ring of mechanical packings
 - Work program
 - Testing facilities
 - Results
 - Conclusions

A regional, national and international player

The French mechanical centre close to its 6,500 subscribing companies

3 main sites:
Senlis, Nantes, Saint-Etienne

19 delegations

4 associated centres




2 resource centres: Mechatronics,
Non-destructive testing


2 subsidiaries dedicated to material
testing for production monitoring



Fondationcetim
sous l'égide de la Fondation de France



Scientific issues and technics linked to control and understanding of sealing mechanisms




A triple expertise



Leak measurement expertise



Qualification characterisation



Sealing mechanisms

Our domains of intervention...

Leak measurement expertise

Detection, location, quantification

Activities



Helium leak testings



Alternative leak measurement methods



On site leak measurements



Diagnosis and support

Characterisation Qualification

Products and sealing systems

Activities



Product qualification testings



Components qualification testing



Characterisation test engineering in service conditions




Test bench engineering


Sealing mechanisms

Sealing systems modelling and analysis

Activities




Design tools



Sealing systems modelling



Material analysis and sealing performances improvment



Selection support/ sealing system design



Failure analysis



Example n°1 : Qualification of low friction valve packings for nuclear applications



Introduction

- Friction forces of valve packings are identified by EDF as an axis of improvement to avoid either changes of electric actuator or heavy and expensive modifications of valves.
- In this context, packing manufacturers have developed graphite and PTFE low-friction packings whose performance must be known.
- From 2015 to 2018, in this project for nuclear applications, several types of packing are tested for
 - Corrosion at ambient and high temperature.
 - Cycling tests are performed to determine their sealing and friction performances.
 - And cycling tests coupled with irradiation phases are carried out to qualify their resistance to radiation.

Outlook

- Work program
- Testing facilities
- Results
- Conclusions

Qualification of low friction valve packings for nuclear applications.

Work program

- **Type of testing packing**

- PTFE braided rings + braided graphite end rings from various packing manufacturers



Material	
Sealing ring	PTFE
End ring	Graphite

- Expanded graphite rings + braided graphite end rings from various packing manufacturers




Material	
Sealing ring	Graphite
End ring	Graphite


Qualification of low friction valve packings for nuclear applications.

Work program

functional qualification under normal conditions






functional qualification under accidental conditions



Testing facilities and procedures



22/05/2019

Corrosion test bench	Ambient temperature	High temperature
		
Test procedure	5 weeks	5 weeks
Pressure	Wet air	90 bar - demineralized water
Compression	30 MPa	30 MPa
Temperature	Room Temperature (tRT)	300°C
Analysis	Optical and Scanning Electron Microscope	
Criterion	No corrosion	



Qualification of low friction valve packings for nuclear applications.

Testing facilities

22/05/2019





Testing facilities and procedures




Testing facilities and procedures

22/05/2019




Testing facilities and procedures

22/05/2019



Irradiation source
locations



Temperature : 70°C (+/- 3°C)
 Atmosphere : air
 Dose rate : 8 kGy/h
 Total dose : 250 kGy
 + 600 kGy (850 kGy)
 + 1150 kGy (2MGy)
 + 2000 kGy (4 Mgy)

Oven

Qualification of low friction valve packings for nuclear applications.



Results



Specimen after corrosion test at room temperature



Specimen after corrosion test at high temperature




Corrosion test	Ambient temperature	High temperature
PTFE 1	No corrosion	No corrosion
PTFE 2	No corrosion	No corrosion
Graphite 1	No corrosion	No corrosion
Graphite 2	No corrosion	No corrosion
END RING 1	No corrosion	No corrosion
END RING 2	No corrosion	No corrosion

Qualification of low friction valve packings for nuclear applications.

Results

- Cycling tests
- Graphite
 - Leakage <5 ml/h
 - Friction K is lower than the previous packing generation at the beginning of the test (around -28 %)
 - However friction coefficient increases with cycles without exceeding 12
 - $K \approx 12$ at the end without pressure
- PTFE
 - Leakage <5 ml/h
 - Friction K is around 4-5 at the beginning of the test and decreases down to values lower than 1
 - $K \approx 2$ at the end (without pressure)



Qualification of low friction valve packings for nuclear applications.

Results


Irradiation test : graphite

- Leakage <5 ml/h (during cycling)
- Leakage <50 ml/h (after irradiation)
- Friction K is lower than the previous packing generation at the beginning of the test

- Friction coefficient K remains stable with cycling
- $K \approx 9$ (dry, tRT)
- $K < 6$ (200 barg, 300°C)
- $K \approx 8-10$ (0 barg, tRT)
- K remains constant even after 4 MGy (no detectable degradation even after 4 MGy irradiation)


Irradiation test : PTFE

- Leakage <5 ml/h (during cycling)
- Leakage <50 ml/h (after irradiation)
- $K \approx 2-5$ (dry, tRT)
- $K < 1$ (185 barg, 250°C)
- $K \approx 1-2$ (0 barg, tRT)
- K remains constant even after 4 MGy (no detectable degradation even after 4MGy irradiation)




Qualification of low friction valve packings for nuclear applications.

Results



Brown particles with PTFE packing




White powder from Graphite packings




PTFE Packing after irradiation

Except a slight extrusion, no significant packing damage



Conclusions

- Test procedures and test installations were developed by CETIM
- Various tests are performed :
 - ✓ Two types of braided PTFE and expanded graphite packings with graphite end rings
 - ✓ Corrosions test at ambient and at high temperature
 - ⇒ No corrosion is observed both for PTFE and graphite packing
 - ✓ Cycling tests
 - ⇒ Leakages remain under thresholds
 - ⇒ Frictions are lower than the previous products. However, for graphite packings, friction is increasing with number of cycles without exceeding 12. For PTFE packings, friction coefficient K decreases down to values lower than 1
- Irradiation tests
 - ⇒ Tests show that graphite and PTFE packings can support cumulated doses up to 4 MGy after 1500 cycles



Example n°2 : Qualification of static and semi-dynamic O-ring of mechanical packing



Introduction

Development of ultimate safety pumps needs the development of high performances mechanical seals.

LATTY International was solicited for study and conception of mechanical packings.

Considering service conditions, LATTY International chose a mechanical packing with static springs out of product.

The aim of this study was testing capacity of seals to resist to a high dose of irradiation after ageing representing its cycle of life.

It is then to qualify elastomeric semi-dynamic and static O-rings to accidental irradiations.

Outlook of this presentation

- Work program
- Testing facilities
- Results
- Conclusions

Work program


Type of Sealing material :

- O-rings : 4 different materials (L1 to L4) from various manufacturers








- 2 cells per material (cell 1: O-rings L11-L12, cell 2: O-rings L13-L14 for material 1)

Work program



Test facilities and procedure

22/05/2019

Conditions	Mechanical ageing	Thermal ageing	Accidental thermal ageing	Irradiation
				
Duration (h)	500	252	72 / 175	~1200
Pressure of water (Bar)	12	12	12	N.a.
Temperature (°C)	Room	120	140 / 130	70
Frequency (Hz)	5	N.a.	N.a.	N.a.
Amplitude (mm)	± 0,3	N.a.	N.a.	N.a.
Irradiation (kGy)	N.a.	N.a.	N.a.	600 / 1000 / 1700
Criterion	No leak	No leak	No leak	No leak 400% of initial stress

Testing facilities: mechanical ageing

22/05/2019




Piston



Sleeve with 2 O-rings

Data acquisition system



Cells

Engine



Stress gauge

Leak measurement

- Measurement of stress with a gauge
- Measurement of strain with a calibrated laser



In case of leak, each cell can be isolated


Testing facilities : thermal and accidental ageing

22/05/2019



Testing facilities : irradiation

22/05/2019




Temperature : 70°C
Atmosphere : air
Dose rate : 1,5kGy/h
Total dose : 600 ; 1000; 1700kGy



Dosimeters
on front side



Dosimeters
on back side



Dosimetry test

Results : Preliminary tests


- **Measurement of leak: weighing a tissu before and after hydrolic test**
- Calibration of droplet mass
- Evaporation of water in tissu during time
- Conclusions
 - A droplet weight is 22mg
 - Evaporation of water is ~20mg in 10 min
 - Measurement should be done in less than 10 minutes after end of hydrolic test



Results : Tests

Measurement of stress and strain:

Tangential force



- **Partial sliding:** no integral displacement in contact zone of the seal.

During cycling, hysteresis (stress/strain) is elliptical.

Slope = stiffness. It depends on pressure and contact length, geometry and mechanical behaviour of the seal






- **Total sliding:** contact surface of the seal moves totally from the face against it. Sliding then happens.

During cycling, hysteresis is dilated with constant stress while sliding begins.

Solicitations lead to particular friction which can damage the surface of the seal.

Results : initial test






- **Hardness of elastomers:** variation between 65 an 75 shore A
- **Measurement of stress and strain:** partial and total sliding



- **Leakage :** no leakage on 8 cells + 2 cells with L7



Results : tests after mechanical ageing

Leak of material 3 O-rings during mechanical ageing, replaced by material 7



Results : tests after thermal ageing



22/05/2019



No leak observed

Results : tests after accidental thermal ageing

22/05/2019




1 leak observed on L23 after hydrostatic test 1: 1,07cm³/h
No leak when pressure relieved


Limited accepted = 5,33cm³/h

Results : Tests after Irradiation test


22/05/2019

Average irradiation temperature: $(71.6 \pm 1.4) ^\circ\text{C}$ 


Stress/Strain final curve vs initial curve (L1)




Stress/Strain final curve vs initial curve (L2)



Stress/Strain final curve vs initial curve (L3)



Stress/Strain final curve vs initial curve (L7)




After irradiation,

Cell still water: L11/L12; L13/L14; (L41/L42); L43/L44

Cell without water: L21/L22; L23/L24; L71/L72; L73/L74

Results : final tests



Conclusions

- From solicitations defined in LATTY International specifications, Cetim developed a test bench allowing to :
 - Achieve a short and quick friction test
 - Test O-rings in their grooves not only at room temperature but also in high temperature with circulation of water
 - Isolate cells full of water to irradiate O-rings with their sealing function
- O-rings in material called **Latty 1 and Latty 4 fill the criteria**: final hydrostatic test at 8,5 14 and 25 bars during 15 minutes + final stress < 400% of initial stress (after 90 cycles).
- O-rings in material called **Latty 3** presented a **leak during mechanical ageing**. They did not meet the criteria. They were replaced by material called Latty 7.
- O-rings in material called **Latty 2** presented a **leak** during hydrostatic test after an irradiation of more or less **600kGy**.
- O-rings in material called **Latty 7** presented a **leak** during hydrostatic test after an irradiation of more or less **1000kGy**.

QUALIFICATION OF LOW FRICTION VALVE PACKINGS FOR NUCLEAR APPLICATIONS.

Emmanuel SAUGER⁽¹⁾, L. Biringer⁽²⁾, and J. Leray⁽¹⁾

*⁽¹⁾ CETIM, 74 route de la Jonelière-CS 50814
44308 Nantes cedex 03 (France)*

*⁽²⁾ EDF - DIPNN - DT - CEE
19 rue Pierre Bourdeix- CS 803269363 - LYON CEDEX 07
(France)*

E-mail : Emmanuel.Sauger@cetim.fr

QUALIFICATION OF STATIC AND SEMI-DYNAMIC O-RING OF MECHANICAL PACKING

Fanny DESTAING⁽¹⁾, M. Adjemout⁽²⁾

*⁽¹⁾ CETIM, 74 route de la Jonelière-CS 50814
44308 Nantes cedex 03 (France)*

*⁽²⁾ Latty
1 Rue Xavier Latty, 28160 Brou (France)*

E-mail : Fanny.Destaing@cetim.fr

THANK YOU FOR ATTENTION!



Towards the future